

Environmental Protection Agency

Pt. 60, Subpt. Cb, Table 3

schedules for meeting the revised April 28, 2009 emission limits in §60.33b(a), (c), and (d) and the revised testing provisions in §60.38b(b).

(1) Compliance with the revised April 28, 2009 emission limits is required as expeditiously as practicable, but no later than April 28, 2009, except as provided in paragraph (g)(2) of this section.

(2) The owner or operator of an affected facility who is planning an extensive emission control system upgrade may petition the Administrator for a longer compliance schedule and must demonstrate to the satisfaction of the Administrator the need for the

additional time. If approved, the schedule may exceed the schedule in paragraph (g)(1) of this section, but cannot exceed May 10, 2011.

(h) In the event no plan for implementing the emission guidelines is approved by EPA, all designated facilities meeting the applicability requirements under §60.32b shall be in compliance with all of the guidelines, including the revised April 28, 2009 emission limits in §60.33b(a), (b), (c), (d), and §60.34b(a), and the revised testing provisions in §60.38b(b), no later than May 10, 2011.

[60 FR 65415, Dec. 19, 1995, as amended at 62 FR 45120, 45125, Aug. 25, 1997; 71 FR 27333, May 10, 2006]

TABLE 1 TO SUBPART Cb OF PART 60—NITROGEN OXIDES GUIDELINES FOR DESIGNATED FACILITIES

Municipal waste combustor technology	Before April 28, 2009, nitrogen oxides emission limit (parts per million by volume) <sup>a</sup>	On and after April 28, 2009, nitrogen oxides emission limit (parts per million by volume) <sup>a</sup>
Mass burn waterwall .....	205 .....	205.
Mass burn rotary waterwall .....	250 .....	210.
Refuse-derived fuel combustor .....	250 .....	250.
Fluidized bed combustor .....	180 .....	180.
Mass burn refractory combustors .....	No limit .....	No limit.

<sup>a</sup> Corrected to 7 percent oxygen, dry basis.

[71 FR 27334, May 10, 2006]

TABLE 2 TO SUBPART Cb OF PART 60—NITROGEN OXIDES LIMITS FOR EXISTING DESIGNATED FACILITIES INCLUDED IN AN EMISSIONS AVERAGING PLAN AT A MUNICIPAL WASTE COMBUSTOR PLANT <sup>b</sup>

Municipal waste combustor technology	Before April 28, 2009, nitrogen oxides emission limit (parts per million by volume) <sup>b</sup>	On and after April 28, 2009, nitrogen oxides emission limit (parts per million by volume) <sup>a</sup>
Mass burn waterwall .....	185 .....	185
Mass burn rotary waterwall .....	220 .....	190
Refuse-derived fuel combustor .....	230 .....	230
Fluidized bed combustor .....	165 .....	165

<sup>a</sup> Mass burn refractory municipal waste combustors and other MWC technologies not listed above may not be included in an emissions averaging plan.

<sup>b</sup> Corrected to 7 percent oxygen, dry basis.

[71 FR 27334, May 10, 2006]

TABLE 3 TO SUBPART Cb OF PART 60—MUNICIPAL WASTE COMBUSTOR OPERATING GUIDELINES

Municipal waste combustor technology	Carbon monoxide emissions levels (parts per million by volume) <sup>a</sup>	Averaging time (hrs) <sup>b</sup>
Mass burn waterwall .....	100 .....	4
Mass burn refractory .....	100 .....	4
Mass burn rotary refractory .....	100 .....	24
Mass burn rotary waterwall .....	250 .....	24
Modular starved air .....	50 .....	4